

MRM-700ADU SERIES

Intelligent Manual Pull Stations



MRM-710ADU
Intelligent Addressable
Dual Action Pull Station

MRM-701ADU
Intelligent Addressable
Single Action Pull Station

Features

- Single or Dual Action
- Key resettable
- Permanently attached Intelligent Addressable Module
- High-gloss red enamel finish
- Plastic breakrod
- Mounts on standard single gang box, Secutron's MRM-700 surface metal backbox or MRM-700WP weather proof backbox

Description

Secutron's MRM-700ADU Series provide manual fire reporting. These high quality, die-cast metal Intelligent Fire Alarm Pull Stations are available in either single or dual action configurations with a permanently attached addressable module.

The MRM-700ADU Series stations are available as single or dual-action devices with key resets and a permanently attached addressable module. The addressable pull station has a pair of rotary decimal switches which allows for two digit address setting. Pulling the handle initiates the operation of the addressable module.

All models are available with CAT-30 keys and mount on a standard single gang backbox, Secutron model MRM-700 interior surface metal backbox, or MRM-700WP weather proof backbox.

Operation

The MRM-701ADU Single Action Intelligent Pull Station is operated by pulling down the handle marked "PULL HANDLE" on the front of the station. The MRM-710U Dual Action Intelligent Pull Station is operated by pushing the bar labelled "PUSH BAR" and then pulling down the handle marked "PULL HANDLE". The MRM-700ADU Series Pull Stations are reset by opening the station with the key, placing the handle in the normal upright position and re-locking the station.

Specifications

The manual pull station shall be Secutron's MRM-700ADU Series. Operating instructions shall be in raised English lettering and the unit shall be constructed of high quality die-cast metal and finished in red enamel paint to provide quick identification. Pulling the handle shall initiate immediate operation of the intelligent addressable module. All manual fire alarm stations shall be installed as per the specific requirements outlined in the UL codes, as well as all other applicable national or local codes. Final acceptance is subject to the local authority having jurisdiction.

